



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511BQ0214

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	FILINOX S.A. C/Sant Adria N° 76, E-08030 Barcelona
Distributor <i>Vertreiber</i>	FILINOX S.A. C/Sant Adria N° 76, E-08030 Barcelona
Product Category <i>Produktart</i>	installation systems and system joints: pipe joint for pipes in drinking water installation systems (8511)
Product Description <i>Produktbezeichnung</i>	System connector as a press connector made of stainless steel for pipes made of stainless steel in accordance with DVGW worksheet GW 541
Model <i>Modell</i>	INSTALPRESS
Test Reports <i>Prüfberichte</i>	laboratory control test: 120002974-19 from 12.12.2019 (MPM) mechanical test: 120002974-14 from 11.12.2014 (MPM) mechanical test: 120002974-13 from 29.11.2013 (MPM) mechanical test: 120002974-12 from 20.12.2012 (MPM) mechanical test: 120001982 from 27.04.2004 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 534 (01.05.2004) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	09.05.2025 / 20-0187-WNV

7.0028-04-A-DE

16.04.2020 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
INSTALPRESS	nominal diameter: 76,1 mm	
INSTALPRESS	nominal diameter: 88,9 mm	
INSTALPRESS	nominal diameter: 108 mm	

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registr.-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
DW-5253BQ0461	sealing material for drinking water installations	TIMO-70/TIMO-70	Tecnogomma International S.p.A.

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Press connectors to be used: metal, type M-MM, FILINOX S.A.

The test was carried out with stainless steel pipes in accordance with DVGW worksheet GW 541.