

## HMER.EX27997 - Check Valves

## Check Valves

[See General Information for Check Valves](#)**ATUSA GRUPO EMPRESARIAL S A**

EX27997

POL IND ATUSA-AGURAIN S/N

SALVATIERRA

01200 ALAVA, SPAIN

Model	Type	Valve Seat Facing	Nom Pipe Size, NPS	End Config	Rated Pressure, psig	Installation Position
650	Split-clapper	Elastomeric	2, 2-1/2, 3, 4, 5, 6, 8, 10, 12, 14, 16	W	232	H, V
640	Swing	Elastomeric	2, 2-1/2, 76.1mm, 3, 4, 6, 165.1mm, 8, 10, 12	G by G	300	H, V
641	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	G by G	300	H, V
645-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
645-PN16	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V
646-300	Swing	Elastomeric	2, 2-1/2, 3, 4, 6, 8, 10, 12	F by F	300	H, V

End Configuration:

F - Flanged

G - Grooved

W - Wafer

Installation Position:

H - Horizontal installation

V - Vertical installation

[Last Updated](#) on 2019-07-09

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"